



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert No. GYJ06441

This is to certify that the product

Pressure Transmitter

manufactured by ABB SACE S.p.A

(Address: Via Statale 113, 22016 Lenno (Como), Italy)

which model is 364□EP□Series

Ex marking Ex d II CT6; Ex ia II CT4~T6; Ex nL II CT4~T6

product standard —

drawing number DH 3068、DH3069、DH 3070

has been inspected and certified by NEPSI, and that it conforms
to GB3836.1/2/4 - 2000、GB3836.8 - 2003

This Approval shall remain in force until 2011.09.19

- Remarks
1. Temperature classification & Special requirements for safe use specified in the attachment to this certificate.
 2. Associated apparatus: see attachment to this certificate.

Director

National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date 2006.09.20



This Certificate is valid for products compatible with the documents and samples approved by NEPSI.



防爆合格证

证号: GYJ06441

由 ABB SACE 有限公司
(地址: Via Statale 113, 22016 Lenno (Como), Italy)

制造的产品:

名称 压力变送器

型号规格 364□EP□系列

防爆标志 Ex d II CT6; Ex ia II CT4~T6; Ex nL II CT4~T6

产品标准 —

图样编号 DH 3068、DH 3069、DH 3070

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB3836.1/2/4 - 2000、GB3836.8 - 2003 标准, 特颁发此证。有效期自颁发日期起伍年内有效。

备注 1. 温度组别和产品使用注意事项见本合格证附件。
2. 关联设备要求见本合格证附件。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期 二〇〇六年九月二十日



本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: 0086 21 64368180
传真: 0086 21 64844580