


# Confirmation of requirements according to EN 60 439-1 annex E

Confirmation of basic requirements when standard EN 60 439-1 refers to agreement between manufacturer and user. The sections below refer to corresponding section in the standard. Fill in appropriate alternative for each section below.

Section in the standard		Normal design	Other design agreed on
4.7	Rated diversity factor	<input type="checkbox"/>	
6.1.1.2	(Note) Use of assemblies in an arctic climate	<sup>1)</sup>	
6.1.3	(Note) Use of electronic equipment at altitudes above 1000 m	<input type="checkbox"/>	
6.2	Special service conditions	<input type="checkbox"/>	
6.2.10	Electrical and radiated interferences	<input type="checkbox"/>	
6.3.1	Conditions during transport, storage and erection	<input type="checkbox"/>	
7.1.3	Terminals for external conductors	<input type="checkbox"/>	
7.2.1.1	Degree of protection considering intended installation, also against the floor	<input type="checkbox"/>	
7.3	Temperature rise allowed for horizontal busbar system	<input type="checkbox"/>	
7.4.2	Choice of protective measure against direct contact	<input type="checkbox"/>	
7.4.3	Choice of protective measure against indirect contact	<input type="checkbox"/>	
7.4.6	Accessibility in service by authorized personnel	<input type="checkbox"/>	
7.4.6.1	Accessibility for inspection and similar operations	<input type="checkbox"/>	
7.4.6.2	Accessibility for maintenance	<input type="checkbox"/>	
7.4.6.3	Accessibility for extension under voltage	<input type="checkbox"/>	
7.5.2.3	Values of prospective short-circuit current for an assembly in case of several incoming or outgoing units for high-power rotating machines	<input type="checkbox"/>	
7.5.4	Co-ordination of short-circuit protective devices	<input type="checkbox"/>	
7.6.4.3	Degree of protection after removal of removable or withdrawable part	<input type="checkbox"/>	
7.7	Form of internal separation	<input type="checkbox"/>	
7.9.1	Input voltage variations for electronic equipment supply	<input type="checkbox"/>	
7.9.4 <small>item b)</small>	Supply frequency deviation	<input type="checkbox"/>	
7.10.1	Environment 1 (Public network) considering EMC <sup>2)</sup> alt.environment 2 (Industrial network) considering EMC <sup>2)</sup>	<input type="checkbox"/> <input type="checkbox"/>	
8.2.1.3.4	Temperature-rise test for values of test current higher than 3150 A	<input type="checkbox"/>	
8.2.1.6	Ambient air temperature during temperature-rise test	<input type="checkbox"/>	
8.2.3.2.3 <small>item d)</small>	Value of test current in the neutral bar at short-circuit withstand test	<input type="checkbox"/>	
8.3.1	Repetition of electric operation test on site	<input type="checkbox"/>	
Documentation	Customer documentation: Extent and form	<input type="checkbox"/>	
Labels	Labels on cubicles	<input type="checkbox"/>	
	Labels on apparatus units	<input type="checkbox"/>	
	Phase marking of horizontal busbars	<input type="checkbox"/>	

<sup>1)</sup> Only applicable for outdoor installations

<sup>2)</sup> Only one of the alternatives to be chosen

					Issued by	Dept	Year	Week	Quotation No	Cont -
									Order No	Sheet 1
Rev ind	Revision	Appd	Year	Week		ABB Installation				