



Translation

EC-Type Examination Certificate

(1)

EC-Type Examination Certificate

(2)

**- Directive 94/9/EC -
Equipment and protective systems intended for use
in potentially explosive atmospheres**

(3)

DMT 02 ATEX E 068 X

(4)

**Equipment: Temperature-Transmitter
Typ TF 02-Ex, TF 102-Ex, TF 202-Ex und TF 202-Ex M**

(5)

Manufacturer: ABB Automation Products GmbH

(6)

Address: D - 63754 Alzenau

(7)

The design and construction of this equipment and any acceptable variation thereto are specified in the schedule to this type examination certificate.

(8)

The certification body of Deutsche Montan Technologie GmbH, notified body no. 0158 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament and the Council of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the test and assessment report BVS PP 02.2040 EG.

(9)

The Essential Health and Safety Requirements are assured by compliance with:

EN 50014:1997 + A1 - A2 General requirements
EN 50020:1994 Intrinsic safety
EN 50284:1999 Equipment Group II Category 1G
EN 50303:2000 Equipment Group I Category M1

(10)

If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11)

This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to Directive 94/9/EC.
Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate

(12)

The marking of the equipment shall include the following:

Ex II 1G or **Ex I M1** (details see 15.1)

Deutsche Montan Technologie GmbH

Essen, dated 25. April 2002

Signed: Dr. Jockers

Signed: Dr. Eickhoff

DMT-Certification body

Head of special services unit



(13) Appendix to

(14) **EC-Type Examination Certificate**

DMT 02 ATEX E 068 X

(15) 15.1 Subject and type

Temperature-Transmitter

Type TF 02-Ex Sensor-head transmitter Ex II 1G EEx ia IIC T6 or Ex I M1 EEx ia I

Type TF 102-Ex Sensor-head transmitter in series-rail housing Ex II 1G EEx ia IIC T6 or Ex I M1 EEx ia I

Type TF 202-Ex Sensor-head transmitter in field housing Ex II 1G EEx ia IIC T6

Type TF 202-Ex M Sensor-head transmitter in stainless steel field housing Ex I M1 EEx ia I

15.2 Description

The Temperature-Transmitters are used as measured value sensors to detect, amplify and transfer measured values in intrinsically safe circuits. Supply and communication of the values are effected via an intrinsically safe fieldbus.

15.3 Parameters

15.3.1 Supply/communications circuit in the type of protection EEx ia IIC or EEx ia IIB
 Connection for type TF 02-Ex via terminals or solder terminals (+) and (-)
 Connection for type TF 202-Ex and TF 202-Ex M via terminals (+) and (-)
 Connection for type TF 102-Ex via terminals 31 and 32 (Circuit 1) and Terminals 41 and 42 (Circuit 2)

For connection to intrinsically safe circuits with the following maximum values in accordance with the FISCO/ENTITY-concept:

				IIC
Maximum input voltage	U_i	DC	24	V
Maximum input current	I_i		360	mA
Maximum input power	P_i		2,52	W
				IIB
Maximum Input voltage	U_i	DC	24	V
Maximum Input current	I_i		380	mA
Maximum Input power	P_i		5,32	W
Maximum internal capacitance	C_i		5	nF
Maximum internal inductance	L_i		10	μ H

15.3.2 Measurement circuit in the type of protection EEx ia IIC or EEx ia IIB

Connection for type TF 02-Ex via terminals or solder terminals 1, 2, 3 and 4

Connection for type TF 202-Ex and TF 202-Ex M via terminals 1, 2, 3 and 4

Connection for type TF 102-Ex via terminals 11, 12, 13 and 14 (circuit 1) and terminals 21, 22, 23 and 24 (circuit 2)

Maximum output voltage	U_o	DC	5,5 V
Maximum output current	I_o		25 mA
Maximum output power	P_o		35 mW
Characteristic: linear			

Maximum internal capacitance	C_i		60 nF
Maximum internal inductance	L_i		negligible

For the connection of passive sensors, refer to the following table for the maximum permitted values for C_o and L_o :

L_o in mH	IIC	IIB
	C_o in μ F	C_o in μ F
2	2.6	15
1	2.9	17
0.5	3.6	21
0.2	4.5	27

For the connection of active sensors with the maximum values $U_o \leq 1,2$ V, $I_o \leq 50$ mA, $P_o \leq 60$ mW, C_i and L_i negligible small, refer to the following table for the maximum permitted values for C_o and L_o :

L_o in mH	IIC	IIB
	C_o in μ F	C_o in μ F
2	1.6	9.8
1	1.9	12
0.	2.3	14
0.2	3.0	19

15.3.3 Display/Service interface in the type of protection EEx ia IIC or EEx ia IIB,

only for type TF 02-Ex, TF 202-Ex and type TF 202-Ex M; connection via 6-pin edge connector

Maximum Output voltage	U_o	DC	8,7 V
Maximum Output current	I_o		55 mA
Maximum Output power	P_o		74 mW
Characteristic: linear			

Refer to the following table for the maximum permitted values for C_o and L_o :

L_o in mH	IIC	IIB
	C_o in μ F	C_o in μ F
2	0.8	2
1	0.8	3
0.5	0.8	3
0.2	1	4

15.3.4 Ambient temperatures or temperatures at the installation site

Equipment Group II, for use in zones of category 1 (Zone 0)	
Temperature class T1 ... T5	- 20 °C to + 60 °C
Temperature class T6	- 20 °C to + 50 °C
Equipment Group II, for use in zones of category 2 (Zone 1)	
Temperature class T1 ... T4	- 40 °C to + 85 °C
Temperature class T5	- 40 °C to + 65 °C
Temperature class T6	- 40 °C to + 50 °C
Equipment Group I, for use in zones of categories M1 and M2	- 20 °C to + 60 °C

(16) Test and assessment report
BVS PP 02.2040 EG as of 25.04.02

(17) Special conditions for safe use

- 17.1 The Temperature-Transmitter Type TF 02-Ex and TF 102-Ex have to be installed in a housing which guarantee a minimum type of protection IP20 in accordance with EN 60529.
- 17.2 When using the Temperature-Transmitter Type TF 02-Ex, TF 102-Ex and TF 202-Ex M in underground mines which are endangered by mine gas and/or inflammable dust (Equipment Group I, Categories M1 and M2), interconnections with other intrinsically safe circuits have to be separated tested and certificated.
In addition, the incorporation of the Temperature-Transmitter Types TF 02-Ex and TF 102-Ex into suitable housings (IP54) have to be separated tested and certificated.
- 17.3 The Temperature-Transmitters are suitable for the following ambient temperatures or installation site temperatures:


Equipment Group II, for use in zones of category 1 (Zone 0)	
Temperature class T1 ... T5	- 20 °C to + 60 °C
Temperature class T6	- 20 °C to + 50 °C
Equipment Group II, for use in zones of category 2 (Zone 1)	
Temperature class T1 ... T4	- 40 °C to + 85 °C
Temperature class T5	- 40 °C to + 65 °C
Temperature class T6	- 40 °C to + 50 °C
Equipment Group I, for use in zones of categories M1 and M2	- 20 °C to + 60 °C

We confirm the correctness of the translation from the German original.
In the case of arbitration only the German wording shall be valid and binding.

45307 Essen, 04.09.2002
BVS-Rip/Mi E 1470/02

Deutsche Montan Technologie GmbH


DMT-Certification body


Head of special services unit




Fachstelle für
Sicherheit elektrischer
Betriebsmittel - BVS

Carl-Beyling-Haus
Dinnendahlstraße 9
44809 Bochum

Telefon 02 01 - 17 2-39 23
Telefax 02 01 - 17 2-39 24

Änderungsinformation – Revision Report

Prüfprotokoll – Test and Assessment Report BVS PP 02.2040 EG



DAR-Reg.-Nr.:
ZLS-P-359-2/01

Die mit folgender Dokumentation festgelegte Änderung hat keinen Einfluss auf die in o.g. Prüfprotokoll getroffenen Festlegungen.

The modification as defined in the following documentation does not influence the details of the aforementioned test and assessment report.


Dokumentation – Descriptive Documents

Beschreibung (2 Bl.) – Description (2 pages), unterschrieben am –signed 08.09.03

Zeichnung Nr. – Drawing no.	vom - dated	unterschrieben am - signed
TF02 B X	22.01.02/01.09.03	08.09.03
04820-01MOP-213428A	26.08.03	08.09.03
04820-01EBL-213428A	26.08.03	08.09.03
04820-01BPB-213428A	26.08.03	08.09.03
04820-01SLB-213428A	26.08.03	08.09.03
04820-01FRP-213428A	26.08.03	08.09.03
0216061 P1 (2)	09.03.01/08.09.03	08.09.03

44809 Bochum, den 25.09.2003
BVS-Rip/Mi A 20030723

EXAM BBG Prüf- und Zertifizier GmbH
Fachstelle für Sicherheit elektrischer Betriebsmittel - BVS


Der Sachverständige - The Testing Officer

1

2

3


4

A

Montageplan

ABB Automation Products GmbH
Borsigstraße 2
D-63755 Alzenau

08.09.03



PRÜFUNGSUNTERLAGE ZU
AI BVS PP 02.2040 EG
VOM 25.09.2003
EXAM - BVS BOCHUM

- 1 = Platine
2 = Buchse, 2x3-Pin, SMD, Platinenunterseite
3 = C1, C2, C3 : $\leq 3,3nF \pm 10\%$, Form 1206, Platinenunterseite
4 = Verbindungsdraht
5 = Lötpad für Verbindungsdraht, Platinenunterseite
6 = Kabelöse M3
7 = Löt- bzw. Krimpstelle

Maßstab 2:1

E

F

CAD-File: TFEMVP1L.PIC		V1-1	26.08.03	Zeichnungs Nr.: 04820-01MOP-213428A	
		2003	Datum	Name	Benennung :
		Zeichn.	26.08.03	A. Wolf	TF02 Filter-Modul
		Bearb.			
		Gepr.	26.08.03	Deckmann	
		Norm			
				Prod.Nr.: 83010-4820	
				Sach-Nr.:	
				213428-TFE-A	
01					
Zust	Änderung	Datum	Name	ges. Blatt 8	Blatt: 1
				Ers. fuer:	Teilekl.: