



Certificate

PROFIBUS Nutzerorganisation e.V. grants to

ABB Automation Products GmbH
Schillerstr. 72, 32423 Minden, Germany

the Certificate No.: **Z00879** for the PROFIBUS Slave:

Product Name: 2600T Pressure 263/265 2000T
Revision: 1.03; SW/FW: 0.24; HW: 8
GSD: ABB_04C2.gsd; Profile: PA139700.gsd

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	DP-V0	MS0, Set_Slave_Address
<input checked="" type="checkbox"/>	DP-V1	MS2
<input type="checkbox"/>	DP-V2	
<input checked="" type="checkbox"/>	Profile	PA Devices V 3.0
<input checked="" type="checkbox"/>	Physical Layer	MBP

Test Report Number: **027-01**
Authorized Test Laboratory: **ifak, Magdeburg, Germany**
Expiry date of Certificate: **June 24, 2009**

The tests were executed in accordance with the following documents:
"Test Specifications for Field Devices according to "PROFIBUS-PA Profile for Process Control Devices, Version 3.0", Version 3.1".
This certificate is granted according to the document "Framework for testing and certification of PROFIBUS products".

Karlsruhe, June 21, 2007



(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.

(K.-P. Lindner)
(Prof. K. Bender)