

Content

1 Device - Revision Record / What is new? 1

1.1 Hardware 1

1.2 Software..... 1

2 DTM - Engineer IT Device Type Manager 1

2.1 Supported devices 1

2.2 DTM Version record / What is new? 1

2.3 Requirements 1

2.3.1 PC-Hardware, Operating system 1

2.3.2 Frame application / compatibility 2

2.4 Installation and configuration 2

2.4.1 Installation..... 2

2.4.2 Uninstall instructions 2

2.5 Update- / Upgrade instructions 2

2.6 Known problems and limitations 2

2.7 Getting help / further information 2

2.8 How to get the Software (driver)? 2

2.9 Licensing the DTM..... 2

1 Device - Revision Record / What is new?

1.1 Hardware

Released Revision	Released Date	Remarks
01.00	21.04.2002	First release

1.2 Software

Released Revision	Released Date	Remarks
01.00	21.04.2002	First release

2 DTM - Engineer IT Device Type Manager

2.1 Supported devices

- 2600T Series Safety Pressure Transmitters 268xx-HART
 - Differential Pressure
 - Gauge Pressure
 - Absolute Pressure

2.2 DTM Version record / What is new?

- DTM SA2600-HART Version 01.00.04
Compatible to FDT 1.2 frame applications.

Released Version	Released Date	Remarks
01.00.00	12.09.2003	First release
01.00.01	06.03.2004	Updated material table with new codes
01.00.02	14.09.2005	Introduced some bugfix and a new Setup
01.00.03	04.10.2005	Bugfix. Updated some DTM Activex components and other parts in order to be conform to the DTMInspector Ver: 1.01.21
01.00.04	31.03.2008	Bugfix. Correction of the "Identification" page management for the TAG and Descriptor display

2.3 Requirements

2.3.1 PC-Hardware, Operating system

- Minimum requirement
 - Intel Pentium III Processor 450 MHz or compatible.
 - 256 MB RAM memory.
 - 300 MB free hard disk space.
 - Windows 2000 / XP.
 - Internet Explorer 6.0.
 - Adobe Reader latest version
 - Member of the "Administrators" group

The ABB DTM SA2600-HART (268) is released for Windows 2000 and Windows XP (Home / Professional) as PC / Notebook installation.

2.3.2 Frame application / compatibility

- The FDT compatibility was tested with the dtmINSPECTOR Rev. 1.01.21.

Therefore the ABB DTM should be usable in all frame applications according to the requirements of FDT 1.2.

Please read the respective frame application documentation, too

2.4 Installation and configuration

2.4.1 Installation

- Make sure that the minimum hardware requirements are met.
- Start Windows (login with administrator rights!).
- Cancel all running programs.
- Insert CD-ROM or unpack the DTM zip file available as download from www.abb.com/Instrumentation.
- Start "Setup.exe" in the directory DTM\DTM SA2600-HART of the CD-ROM or in the directory you have chosen for the software downloaded from the Internet.
- Follow the instructions.

2.4.2 Uninstall instructions

- In the operating system: "Start -> Settings -> Control Panel -> Add/Remove Programs -> Install/Uninstall" -> Select the DTM and Uninstall.

2.5 Update- / Upgrade instructions

- Uninstallation is not needed before update / upgrade. It can be handled like a new installation, existing projects will be kept.
- Hints regarding new versions may be found under <http://www.abb.com/Fieldbus>

2.6 Known problems and limitations

- The dialouge language is available in English only.
- Valid for FDT frame applications only:
 - TAG cannot be set via a DTM.
In DSV401 (SMART VISION) this limit does not apply.
 - DTM cannot switch to Offline mode if working with Online Application. Device has to be disconnected first and then the DTM can be switched to Offline mode only.
In DSV401 (SMART VISION) this limit does not apply.
 - It could happen that the list of available functions for a DTM in the frame application does not get updated. If that happens, click on "New project" in the frame and when prompted to save click on "Cancel". The DTM menu with all functions in the frame will be available again.
 - In DSV401 (SMART VISION) this limit does not apply.

2.7 Getting help / further information

- Press 'F1' for online help. Help concerning the integration of the DTM in the FDT frame application can be found in the respective documentation of the frame application.
- Hints regarding commissioning
 - After connecting the device for the first time, an upload should be performed.
 - After an upload of the device data into the DTM it is recommended to save all data.
- Initialisation of the DTM for the ABB DTM SA2600-HART (268):
For starting the DTM, the ABB DTM SA2600-HART (268) has to be used when creating the project tree. For initialisation select the menu item "More" in the "Device" menu. Depending on the operating speed of the PC this could take some seconds.

- Configuration of the ABB DTM SA2600-HART (268):
- The DTM is started by right-clicking the device menu item or clicking on the SMART VISION "Device" menu entry. In both cases select "Edit". Changed data is displayed in blue and underlined. Using the command "Save data to device" this data will be sent to the device.

More DTM's for transmitter series 2600T

- ABB DTM ST2600-HART
2600T Series Pressure Transmitters 261-HART
- ABB DTM HI2600-HART/PA
2600T Series Pressure Transmitters 264-HART/PA
- ABB DTM SA2600-HART
2600T Series Pressure Transmitters 268-HART
- ABB DTM TO2600-HART
2600T Series Pressure Transmitters 265-HART/PA
2000T Series Pressure Transmitters 2010TD,
2020TG,2020TA, 2010TA (2010TC up to software revision 21)
- ABB DTM MV2600-HART/PA
2600T Series Pressure Transmitters 267/269 HART/PA
2000T Series Pressure Transmitters 2010TC HART/PA
valid from software revision 22/0.22
- ABB DMA MV2600-H1
2600 Series Pressure Transmitters 267/269 H1 (Foundation Fieldbus)
- ABB DTM 364-HART
2600T Series Pressure Transmitters 364-HART

2.8 How to get the Software (driver)?

Please use one of the following ways to get the Software (driver):

- Available on the newest DTM & DSV401 (SMART VISION) CD-ROM

The latest Software (driver) and "Supplementary Information" at one time with hints regarding new versions, known problems and limitations, etc. may be found:

- As download from <http://www.abb.com/Fieldbus>
 - >[select Fieldbus protocol]
 - >[select field device]
 - >[select device group / name]
 - use link read more
 - > go to flag "Fieldbus & HART Files"
- The Aspect Object (*.afw) online file contains all driver and information. For the *.afw file
 - > go to flag "Downloads"

2.9 Licensing the DTM

- The DTM is usable without any license in any frame application.
- After the installation the ABB DTM runs 90-days in demo mode (full functionality) and needs to be purchased within this period, when the storage of data on a PC / Notebook being requested.
- By purchasing the DSV401 (SMART VISION) single PC license the ABB DTM is also operable without restriction and does not have to be ordered separately!

**TABB has Sales & Customer Support
expertise in over 100 countries worldwide.**

<http://www.abb.com/instrumentation>

The Company's policy is one of continuous product improvement and the right is reserved to modify the information contained herein without notice.

Printed in the Fed. Rep. of Germany (04.2008)

© ABB 2008



ABB Ltd.
Howard Road, St. Neots
Cambridgeshire, PE19 8EU
UK
Tel: +44 (0) 1480 475321
Fax: +44 (0) 1480 217948

ABB Inc.
125 E. County Line Road
Warminster, PA 18974
USA
Tel: +1 215 674 6000
Fax: +1 215 674 7183

ABB SACE spa
Via Statale, 113
22016 Lenno (CO)
Italy
Tel: +39 0344 58111
Fax: +39 0344 56278