

*Not to be distributed outside of FM Global except by Customer*

# APPROVAL REPORT

## PRESSURE AND DIFFERENTIAL PRESSURE TRANSMITTER MV-LINE TYPE 20a0 T b c AND TYPE 2600T FOR HAZARDOUS (CLASSIFIED) LOCATIONS

### Prepared for:

**ABB Automation Products GmbH**  
**Schillerstrasse 72**  
**D-32425 Minden, Germany**

**Project ID: 3011340**  
**Class 3610**  
**Date: May 10, 2002**

Factory Mutual Research Corporation  
1151 Boston-Providence Turnpike  
P.O. Box 9102  
Norwood, MA 02062

**Pressure and Differential Pressure Transmitter  
Mv-Line Type 20a0 T b c and Type 2600T  
For Hazardous (Classified) Locations**

May 10, 2002

from

**ABB Automation Products GmbH  
Schillerstrasse 72  
D-32425 Minden, Germany**

**I INTRODUCTION**

- 1.1 ABB Automation Products GmbH. (manufacturer) has requested Approval of the apparatus listed in section 1.4 to be in compliance with the applicable requirements of the following standards listed in section 1.3. ZELM Ex performed the examination and testing of the products for possible Factory Mutual Research Approval based on the inter-laboratory agreement between Factory Mutual Research and ZELM Ex.
- 1.2 This report may be reproduced only in its entirety and without modification.
- 1.3 **Standards:**

<b>Title</b>	<b>Class Number</b>	<b>Date</b>
Electrical Equipment for Use in Hazardous (Classified) Locations, General Requirements	3600	November 1998
Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, & III, Division 1 and Class I Zone 0 & 1 Hazardous (Classified) Locations	3610	October 1999
Nonincendive Electrical Equipment for Use in Class I and II, Division 2, and Class III, Divisions 1 and 2, Hazardous (Classified) Locations	3611	October 1999
Electrical and Electronic Test, Measuring and Process Control Equipment	3810 (Including Supplement #1)	March 1989 (July 1995)
Enclosures for Electrical Equipment (1000 Volts Maximum)	ANSI/NEMA 250	1991

FACTORY MUTUAL RESEARCH  
Project ID: 3011340

1.4 **Listings:** The following was evaluated as Intrinsically safe, with Entity and FISCO parameters, for use in Class I, II, III Division 1, Groups A, B, C, D, E, F, G and Class I, Zone 0, Group IIC, in accordance with manufacturing's Control Drawing No. A 01 M 504 V; nonincendive with nonincendive field wiring for Class I, Division 2, Groups A, B, C, D and Class I, Zone 2, Group IIC, special protection for Class II, Division 2, Groups F, G, in accordance with manufacturing's Control Drawing No. A 01 M 504 V , Hazardous (Classified) Indoor/Outdoor (TYPE 4X) Locations. The product will appear in the Approval Guide as follows:

1.4.1 **20a0 T b c, MV-Line Pressure and Differential Pressure Transmitter**

IS/I, II, III/1/ABCDEFG/ T6, T4 Ta = 85 °C – A 01 M 504 V; Entity; Type 4X

I/O/AEx ia IIC/ T6, T4 Ta = 85 °C - A 01 M 504 V; FISCO

NI/I/2/ABCD/ T6, T4 Ta = 85 °C; - A 01 M 504 V

S/II, III/2/F,G/ T6, T4 Ta = 85 °C

Entity and Nonincendive Field Wiring Parameters:

Groups A, B, C, D, E, F, and G and Group IIC:  $V_{max} = 24V$   $I_{max} = 250mA$   $P_i = 1.2W$   
 $C_i = 1nF$   $L_i = 10\mu H$

FISCO Parameters:

Groups A, B, C, D, E, F, and G and Group IIC:  $V_{max} = 17.5V$   $I_{max} = 360mA$   $P_i = 2.52W$

Groups C, D, E, F, and G and Group IIB:  $V_{max} = 17.5V$   $I_{max} = 380mA$   $P_i = 5.32W$   
 $C_i = 1nF$   $L_i = 10\mu H$

Maximum Entity, FISCO and Nonincendive Field Wiring Parameters: Supply and Sensor Terminals

$V_{oc} = 10.5 V$ ,  $I_{sc} = 1.5 mA$ ,  $C_a = 2.4\mu F$ ,  $L_a = 1H$ ,  $P_o = 4 mW$

a = 1 or 2

b = A, C, D, or G

c = Profibus-PA or Foundation Fieldbus

FACTORY MUTUAL RESEARCH  
Project ID: 3011340

1.4.2 **26abcdefghijklmnpqrst, MV-Line Pressure and Differential Pressure Transmitter**

IS/I, II, III/1/ABCDEFGH/ T6, T4 Ta = 85 °C - A 01 M 504 V; Entity; Type 4X

I/O/AEx ia IIC/ T6, T4 Ta = 85 °C - A 01 M 504 V; FISCO

NI/I/2/ABCD/ T6, T4 Ta = 85 °C; - A 01 M 504 V

S/II, III/2/F,G/ T6, T4 Ta = 85 °C

Entity and Nonincendive Field Wiring Parameters:

Groups A, B, C, D, E, F, and G and Group IIC:  $V_{max} = 24V$   $I_{max} = 250mA$   $P_i = 1.2W$   
 $C_i = 1nF$   $L_i = 10\mu H$

FISCO Parameters:

Groups A, B, C, D, E, F, and G and Group IIC:  $V_{max} = 17.5V$   $I_{max} = 360mA$   $P_i = 2.52W$

Groups C, D, E, F, and G and Group IIB:  $V_{max} = 17.5V$   $I_{max} = 380mA$   $P_i = 5.32W$   
 $C_i = 1nF$   $L_i = 10\mu H$

Maximum Entity, FISCO and Nonincendive Field Wiring Parameters: Supply and Sensor Terminals

$V_{oc} = 10.5 V$ ,  $I_{sc} = 1.5 mA$ ,  $C_a = 2.4\mu F$ ,  $L_a = 1H$ ,  $P_o = 4 mW$

- a = performance 3, 5, 7, 9
- b = measure type and construction A, B, C, D, J, G, V
- c = application C, H, R, S
- d = upper range limits A, C, F, L, N, R, U, V
- e = static pressure range 1, 2, 3, 4, M, Y, C, Z, T, S
- f = TR: diaphragm & fluid N, A, S, J, E, G, U, B, H, P, F, K, Y, V, C, M, R, D, T
- g = flange material & connection A, B, C, D, E, F, G, H, L, P, R
- h = connection material & type B, T, N, A, P, V, Q, U, S, E, K, W, C, F, D, Z, Y, R
- i = connection gasket 5, 6, 8, N
- j = high side: flange, rating size A, B, D, E, G, H, J, K, M, N, P, Q, R, S
- l = high side: flange mat & form E, L, M, N
- m = high side: ext size & material 1, 2, 3, 4, 5, 6, 9, F
- n = high side: isolating diaphragm G, H, K, S, T, Y
- o = high side: fill fluid H, N, P, S, V, W
- p = low side: diaphragm & fluid N, A, S, P, F, K, Y, V, C, M, R, D, T
- q = low side: flanges & connection A, B, C, D, E, F, G, H, L, P, R
- r = bolts and gasket 1, 2, 3, 4, 5, 6, N, R
- s = electronic housing A, B, E, G, J, K, S, T, W, Z
- t = communication 2, 3, F, P

- 1.5 - As described in this report, the construction of the Pressure and Differential pressure Transmitter provides the degree of protection against electrical shock, fire, and injury required for hazardous (classified) locations.

**FACTORY MUTUAL RESEARCH**  
Project ID: 3011340

**II DESCRIPTION**

- 2.1 This report is Factory Mutual Research's addition to ZELM Ex's report No. 0080117 for the manufacturer's Mv-Line Type 20a0 T b c and Type 2600T. The Pressure and Differential pressure Transmitter MV-Line is used for measuring and converting physical values like pressure, differential pressure and temperature into digital standard signals (Profibus-PA or Foundation fieldbus). It can be supplied by an intrinsically safe linear barrier or by a FISCO supply with rectangular or trapezoidal characteristics.
- 2.2 For additional descriptive information, reference the original ZELM Ex report No.0080117.

**III EXAMINATIONS AND TESTS**

The attached ZELM Ex test report, No. 0080117, describes the examination and testing that ZELM Ex performed towards Factory Mutual Research Approval of the products listed in Section 1.4 of this report. A review of the ZELM Ex report found the following examination and testing of the Mv-Line Type 20a0 T b c and Type 2600T to be satisfactory for a Factory Mutual Research Approval. All data is on file at Factory Mutual Research along with other documents and correspondence applicable to this program.

- Intrinsically safe, with Entity and FISCO parameters, for use in Class I, II, III Division 1, Groups A, B, C, D, E, F, G and Class I Zone 0 Group IIC, in accordance with manufacturing's Control Drawing No. A 01 M 504 V; hazardous (classified) locations.
- Nonincendive with Nonincendive Field wiring evaluation for Class I, Division 2, Groups A, B, C and D; hazardous (classified) locations.
- Suitable for Class II, Division 2, Groups F and G, Class III, Division 1; hazardous (classified) locations.
- Process pressure testing on the Mv-Line Type 20a0 T b c and Type 2600T for a maximum working pressure rating of 100 bar (1500 psi).
- Environmental Type 4X examination and testing.
- Examination and testing to verify protection against fire, injury and shock.

**IV MARKING**

The following information appears on the attached drawing number V15712 X125 (4) revision 4 and the apparatus identified in Section 1.4 that meets Standard requirements

- Manufacturer's name, address, model code and serial number
- Maximum input and output ratings
- Maximum ambient temperature and temperature classification
- Hazardous area classification
- The reference to control drawing no. A 01 M 504 V
- The Factory Mutual Research mark of Approval

FACTORY MUTUAL RESEARCH  
Project ID: 3011340

**V REMARKS**

- 5.1 Installations shall comply with the relevant requirements of the latest edition of the National Electrical Code (ANSI/NFPA 70).
- 5.2 Installations shall comply with the latest edition the manufacturer's instruction manual.
- 5.3 Control room equipment connected to intrinsically safe associated apparatus should not use or generate more than 250 V rms or DC.
- 5.4 See ANSI/ISA RP12.6, Installation of Intrinsically Safe Systems for Hazardous (Classified) Locations for guidance on the installation of intrinsically safe apparatus and systems.

**VI FACILITIES AND PROCEDURES AUDIT**

The ABB Automation Products GmbH manufacturing site in Minden, Germany is subject to follow-up audit inspections. The facility and quality control procedures in place have, previously, been found satisfactory to manufacture products identical to that tested and Approved.

**VII MANUFACTURERS RESPONSIBILITIES**

The manufacturer shall advise Factory Mutual Research of all proposed changes to the documents listed in Section VIII via a Form 797, Approved Product Revision Report.

**VIII DOCUMENTATION**

The following drawings depict the Mv-Line Type 20a0 T b c and Type 2600T. These Drawings are on file at Factory Mutual Research in critical document file No. 3011340.

Title	Revision	Document No.
Main Board Fieldbus	06/07/01	V15712 X122(1)
Characterization Board p-piezo	03/30/01	V15712 X114(1)
Characterization Board dp-piezo	03/30/01	V15712 X115(1)
Characterization Board p-cap	05/29/01	V15712 X116(1)
Characterization Board dp-cap	05/04/01	V15712 X117(1)
Characterization Board hp-piezo	04/05/01	V15712 X118(1)
Temp. Board Multivariable	04/05/01	V15712 X119(2)
Connection Board Fieldbus	05/31/01	V15712 X121(2)
LCD-Display	05/29/01	V15712 X120(2)
Type plate	4	V15712 X125(4)
Block diagram MV 2000 Fieldbus	04/05/01	V15712 X113(3)
Transmitter MV 2000T.	04/02/01	V15712 X123(1)
MV20..T. with remote seal	05/23/01	V15712 X127(1)
FM Control Drawing 2000 T	03/15/02	A 01 M 504 V
Ordering Information (8 pages)	05/11/01	V15712 X126(4)
Transmitter Coding (8 pages)	03/15/02	V15712 X174
Component Lists	04/11/01	V15712 X114 P
Component Lists	04/11/01	V15712 X115 P

FACTORY MUTUAL RESEARCH  
Project ID: 3011340

Title	Revision	Document No.
Component Lists	04/11/01	V15712 X116 P
Component Lists	04/11/01	V15712 X117 P
Component Lists	04/11/01	V15712 X118 P
Component Lists	04/11/01	V15712 X119 P
Component Lists	04/11/01	V15712 X120 P
Component Lists	04/11/01	V15712 X121 P
Component Lists	04/11/01	V15712 X122 P
Component Lists	04/11/01	V15712 X1xx P
Component Lists	04/11/01	V15712 X1xx P

**IX CONCLUSION**

The apparatus listed in Section 1.4 meets Factory Mutual Research requirements. Approval is effective when the Approval Agreement is signed and received by Factory Mutual Research.

**EXAMINATION AND TESTING BY:**

- ZELM Ex - Burkhard Gorks


**EXAMINATION BY:**

- Factory Mutual Research - Patrick J. Byrne


**ATTACHMENTS:**

- ZELM Ex Test Report Number 0080117, dated April 23, 2002
- Product Label Drawing, Number V15712 X125 Revision 4
- Installation Drawing Number A01M504V, dated April 15, 2002

**REPORT BY:**

  
Patrick J. Byrne  
Engineer  
Electrical Section

**REPORT REVIEWED BY:**

  
Aaron Coleman  
Engineer  
Electrical Section





Member of the FM Global Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

### **20a0 T b c, MV-Line Pressure and Differential Pressure Transmitter**

IS/I, II, III/1/ABCDEFGH/ T6, T4 Ta = 85 °C – A 01 M 504 V; Entity; Type 4X

I/O/AEx ia IIC/ T6, T4 Ta = 85 °C - A 01 M 504 V; FISCO

NI/1/2/ABCD/ T6, T4 Ta = 85 °C; - A 01 M 504 V

S/II, III/2/F,G/ T6, T4 Ta = 85 °C

Entity and Nonincendive Field Wiring Parameters:

Groups A, B, C, D, E, F, and G and Group IIC: Vmax = 24V I<sub>max</sub> = 250mA Pi = 1.2W  
Ci = 1nF Li = 10μH

FISCO Parameters:

Groups A, B, C, D, E, F, and G and Group IIC: Vmax = 17.5V I<sub>max</sub> = 360mA Pi = 2.52W

Groups C, D, E, F, and G and Group IIB: Vmax = 17.5V I<sub>max</sub> = 380mA Pi = 5.32W  
Ci = 1nF Li = 10μH

Maximum Entity, FISCO and Nonincendive Field Wiring Parameters: Supply and Sensor Terminals  
Voc = 10.5 V, Isc = 1.5 mA, Ca = 2.4μF, La = 1H, Po = 4 mW

- a = 1 or 2
- b = A, C, D, or G
- c = Profibus-PA or Foundation Fieldbus

### **26 abcdefghijklmnopqrst [u], 2600T Pressure Transmitter.**

IS/I, II, III/1/ABCDEFGH/ T6, T4 Ta = 85 °C – A 01 M 504 V; Entity; Type 4X

I/O/AEx ia IIC/ T6, T4 Ta = 85 °C - A 01 M 504 V; FISCO

NI/1/2/ABCD/ T6, T4 Ta = 85 °C; - A 01 M 504 V

S/II, III/2/F,G/ T6, T4 Ta = 85 °C

Entity and Nonincendive Field Wiring Parameters:

Groups A, B, C, D, E, F, and G and Group IIC: Vmax = 24V I<sub>max</sub> = 250mA Pi = 1.2W  
Ci = 1nF Li = 10μH

FISCO Parameters:

Groups A, B, C, D, E, F, and G and Group IIC: Vmax = 17.5V I<sub>max</sub> = 360mA Pi = 2.52W



Groups C, D, E, F, and G and Group IIB:  $V_{max} = 17.5V$   $I_{max} = 380mA$   $P_i = 5.32W$   
 $C_i = 1nF$   $L_i = 10\mu H$

Maximum Entity, FISCO and Nonincendive Field Wiring Parameters: Supply and Sensor Terminals

$V_{oc} = 10.5V$ ,  $I_{sc} = 1.5mA$ ,  $C_a = 2.4\mu F$ ,  $L_a = 1H$ ,  $P_o = 4mW$

A = Performance: 3, 5, 7, or 9

b = Measuring type: A, B, C, D, J, G, or V

c = Application: C, H, R, or S

d = Upper Range Limit: A, C, D, F, L, N, R, U, or V

e = Static Pressure: 1, 2, 3, 4, M, Y, C, Z, T, or S

f = TR Diaphragm & Fluid: N, A, S, J, E, G, U, B, H, P, F, K, Y, V, C, M, R, D or T

g = Flange Material & Connection: A, B, C, D, E, F, G, H, L, P, Q, or R

h = Connection Material & Type: B, T, N, A, P, V, Q, U, S, E, K, W, C, F, D, Z, Y, or R

i = Connection Gasket: 5, 6, 8, or N

j = High Side: Flange, Rating Size: A, B, D, E, G, H, J, K, M, N, P, Q, R, or S

l = High Side: Flange Mat & Form: E, L, M, or N

m = High Side EXT Size and Material: 1, 2, 3, 4, 5, 6, 9, or F

n = High Side: Isolating Diaphragm: G; H; K; S; T; or Y

o = High Side: Fill Fluid: H, N, P, S, V, or W

p = Low Side Diaphragm & Fluid: N, A, S, P, F, K, Y, V, C, M, R, D, or T

q = Low Side: Flanges & Connection: A, B, C, D, E, F, G, H, L, P, Q or R

r = Bolts & Gasket: 1, 2, 3, 4, 5, 6, N, or R

s = Electronic Housing: A, B, C, D, E, G, H, J, K, L, M, N, P, R, S, T, U, V, W, Y, or Z

t = Communication: 2, 3, F, P

u = Options (One or more): A1, A2, A3, B2, B4, C1, C2, C3, C4, C5, C6, C7, E4, E6, EA, EC, F1, H1, H2, H3, L1, M1, M2, M3, M4, P1, P2, P3, P4, Q1, Q2, T1, T2, T3, T4, T5, T6, T7, T8, T9, V1, V2, V3, V4, V5, V6, V7, V8, V9.

## Equipment Ratings:

Intrinsically safe, with Entity and FISCO parameters, for use in Class I, II, III Division 1, Groups A, B, C, D, E, F, G and Class I Zone 0 Group IIC, in accordance with manufacturing's Control Drawing No. A 01 M 504 V;

nonincendive with nonincendive field wiring for Class I, II, III Division 2, Groups A, B, C, D, F, G and Class I, Zone 2, Group IIC, in accordance with manufacturing's Control Drawing No. A 01 M 504 V

special protection for Class II, Division 2, Groups F, G,  
Hazardous (Classified) Indoor/Outdoor (TYPE 4X) Locations

## FM Approved for:

ABB Automation Products  
Schillerstraße 72  
32425 Minden, Germany



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3610	1999
Class 3810	2005
ISA-S12.0.01	1991
ANSI/NEMA 250	1991

Original Project ID: 3011340

Approval Granted: October 8, 2002

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
061218	6/15/07		

FM Approvals LLC

  
Robert L. Martell, Jr.  
Assistant Vice President

6/15/07  
Date