


- 1) DATA COMMUNICATION, RS485 (NOT IN REU 513). USE FIBRE-OPTIC INTERFACE MODULE RER 103 FOR GALVANIC ISOLATION.
- 2) OPTICAL PORT FROM MMI. CONNECTION MADE WITH A SPECIAL OPTICAL INTERFACE CABLE, 1MKC950001-1.
- 3) BINARY INPUT, e.g. BLOCKING
- 4) POWER OUTPUT RELAY, e.g. TRIPPING
- 5) SIGNAL OUTPUT RELAY
- 6) IRF
- 7) AUX. POWER SUPPLY



101 RTXP 18 : RK 926 015-AR
108 REU 513 / REU 523

TEKI PREPARED 10-10-2000 S.Björklund	LITTYY CONCERNING		NIMITYS NAME TERMINAL DIAGRAM OVERCURRENT RELAY REU 513 / REU 523 WITH TEST SWITCH	
TARKASTI CHECKED L.Nähls	TOLERANSSIT TOLERANCES			
HYVÄKSYI APPROVED K.Latva-Rasku	SUHDE SCALE	PROJ	OSASTO DEPT. RSG	LEHTI SHEET 1
PIIRUSTUS NO DRAWING NO 1MRS010250-AAA			PAINOS REVISION A	

MUUTOS REVISION
C
B

ABB ABB Substation Automation Oy