


RELAY TYPE	CURRENT TRANSFORMER	
	PIN 3	PIN 2
REJ515B 400BAA	0,2A	1A
REJ515B 403BAA	1A	5A
REJ525B 412BAA	0,2A	1A
REJ525B 415BAA	1A	5A

- 1) DATA COMMUNICATION, RS485 (NOT IN REJ 515). USE FIBRE-OPTIC INTERFACE MODULE RER 103 FOR GALVANIC ISOLATION.
- 2) OPTICAL PORT FROM MMI. CONNECTION MADE WITH A SPECIAL OPTICAL INTERFACE CABLE, 1MKC950001-1.
- 3) BINARY INPUT, e.g. BLOCKING
- 4) POWER OUTPUT RELAY, e.g. TRIPPING
- 5) SIGNAL OUTPUT RELAY
- 6) IRF
- 7) AUX. POWER SUPPLY



101 RTXP 18 : RK 926 015-AD
108 REJ 515 / REJ 525

MUUTOS REVISION C B

TEKI PREPARED 10-10-2000 S.Björklund	LIITTY CONCERNING	NIMITYS NAME TERMINAL DIAGRAM OVERCURRENT & EARTH-FAULT RELAY REJ 515 / REJ 525		LEHTI SHEET 1
TARKASTI CHECKED L.Nähls	TOLERANSSIT TOLERANCES	PROJ RSG	PIIRUSTUS NO DRAWING NO 1MRS010248-AAA	PAINOS REVISION A
HYVÄKSYI APPROVED K.Latva-Rasku	SUHDE SCALE	OSASTO DEPT. RSG		

ABB ABB Substation Automation Oy