





Postal Address  
S-721 59 Västerås / Sweden

Telephone +46 21 34 20 00  
Fax +46 21 14 69 18

Document identity

**1MRK 000 612-49**

Revision	A
Issued by department	SA/TD
Date	03-12-02
Date of CE-mark	02-12-11
Technical reference	R. Östlund 
Checked by	R. Karlsson 

**Application of this document**

This document is intended for use as an approval for CE-marking of below mentioned products:

**Category**

Family of	Apparatus
-----------	-----------

**Declaration**

We ABB Automation Technology Products AB, Substation Automation, S-721 59 Västerås, Sweden, declare under our sole responsibility that the family:

Phasor Measurement Terminal	Type: RES521, V1.0 acc. to Technical Overview Brochure 1MRK 511 115-BEN
-----------------------------	--

to which this declaration relates is in conformity with the following directives

Directive	EMC Directive 89/336/EEC Low Voltage Directive 73/23/EEC *)
-----------	--

\*) Terminals intended to be energized with ring lug connections do **not** conform with the Low Voltage Directive and are thus **not** CE marked.

Our internal quality control system ensures compliance between the manufactured products and the technical documentation.

**Application of the objects**

The family is intended for use in the industrial environment and to protect high voltage or high power apparatus, and thus normally used in a harsh electromagnetic environment near high voltage apparatus.

**References**

Standards	EN 61000-6-4: 1997 EN 61000-6-2: 1999  EN 60 255-6: 1994 EN 50 178: 1997
-----------	--

Technical Construction File (TCF)	1MRK 000 613-16
-----------------------------------	-----------------

**Authorisation**

Signed by	 Sören Forsman, SA/P
-----------	---

This document must not be copied without our written permission, and the contents thereof must not be imparted to a third party nor be used for any unauthorized purpose. Contrainvention will be prosecuted. ABB AB