



Postal Address
S-721 59 Västerås / Sweden

Telephone +46 21 34 20 00
Fax +46 21 14 69 18

Document identity

1MRK 000612-47

Revision

-

Issued by department

SA/DA

Date

02-11-11

Date of CE-mark

97-10-15

Technical reference

R. Karlsson *PK*

Checked by

R. Östlund *RO*

Application of this document

The document is intended for use as a base for the declaration of installations and systems.

Category

Components

Components for use in installations and systems

Declaration

We **ABB Automation Technology Products AB, Substation Automation, S-721 59 Västerås, Sweden**, declare under our sole responsibility that the family:

COMBIFLEX time overvoltage relay

Types:

RXEDA 1 according to Technical overview brochure 1MRK 509 044-BEN, June 1999

to which this declaration relates is in conformity with the following standard(s) or other normative document(s)

Standards

**EN 61000-6-4: 1997
EN 61000-6-2: 1999
EN 60 255-6: 1994
EN 50 178: 1997**

following the provisions of

Directives

**EMC Directive 89/336/EEC
Low Voltage Directive 73/23/EEC**

Our internal quality control system ensures compliance between the manufactured products and the technical documentation.

Application of the objects

The family is intended for use in the industrial environment and to protect high voltage or high power apparatus, and thus normally used in a harsh electromagnetic environment near high voltage apparatus.

References

Type Test Reports

1MRK 000 323-158

Technical Construction File (TCF)

Not applicable

Authorisation

Signed by

Claudio Marchetti
Claudio Marchetti, SA/P

This document must not be copied without our written permission, and the contents thereof must not be imparted to a third party nor be used for any unauthorized purpose. Contravention will be prosecuted. ABB AB

1MRK000009-49 Rev - Resp.dept.QA Approved 05-09-25/UB File ../ABB/dsign/dcmf2